

From: Mark Tollison <[REDACTED]>
To: Jeffrey Epstein <jeevacation@gmail.com>
Cc: Richard Kahn <[REDACTED]>
Subject: Cause of 9 E 4th Floor Gym Ceiling Falling
Sent: Tuesday, November 5, 2013 6:59:06 PM

Sir,

The coil in original air handler (23 years old) in the 5th floor mechanical room that sends air to the 6 th floor movie room expired.

After finishing clean up today Rich Barnett will request from AD Winston a proposal for a new air handler unit.

New carpet and new ceiling will be required for the gym as well.

Best regards,

Mark

Mark Tollison

The information contained in this e-mail is confidential and is intended solely for the use of the addressee(s) named above. If you are not the intended recipient or the person responsible for delivering this confidential information to the intended recipient, you have received this information in error, and any review, use, dissemination, forwarding, printing, copying, or other distribution of this e-mail message and any attached files is strictly prohibited. The sender reserves the right to monitor any communication that is created, received, or sent on its network. If you have received this confidential communication in error, please notify the sender immediately by reply e-mail message and permanently delete the original communication.