
From: Richard Barnett [REDACTED]
Sent: Thursday, May 2, 2013 5:42 PM
To: jeffrey Epstein
Subject: 484 Greenwich Street Heat/ AC

Hi Mr.Epstein as I reported the XR 80 unit in the basement air conditioning part of the unit was never hooked up by the contractor the owner and realtor had no idea .The owner called the ac contractor and he confirmed he never finished the work. I was also shown the roof top condenser units this time for the ac part of the system which hidden above the roof terrace steel ductage in the wood inclosure which is difficult to access. The AC contractor is meeting with the owner today to discuss finishing the work.

=
=