

---

**From:** Brice [REDACTED]  
**Sent:** Tuesday, October 16, 2012 6:20 PM  
**To:** Richard Kahn  
**Cc:** J Epstein  
**Subject:** Buck Steel  
**Attachments:** photo 1.JPG; Untitled attachment 00233.txt; photo 2.JPG; Untitled attachment 00236.txt; photo 3.JPG; Untitled attachment 00239.txt; photo 4.JPG; Untitled attachment 00242.txt

Rich

Danny and I have reviewed drawings from Buck Steel Please note that the existing bolt pattern that is in place will have to be removed. and new anchors will need to be epoxied in to match shed from buck steel I assume that Jeffrey is ok with Door placement

Would recommend Forward  
Any concerns please call

Regards

Brice