

---

**From:** Richard Kahn <[REDACTED]>  
**Sent:** Friday, January 30, 2015 7:17 PM  
**To:** jeffrey E.  
**Subject:** NES Lutron control

Merwin is working to obtain a quote to upgrade Lutron system =s light control for 4 lights blew out. This will probably not =appen until early next week.  
Lutron no longer services =r has parts for our existing equipment Should we =nstall a switch in panel to control 4 lights (see last picture below) =ight away or wait for Lutron quote to upgrade system Please advise Thank you

Richard Kahn  
HBRK Associates Inc.



<[REDACTED]> wrote:  
> On Jan 28, 2015, at 10:41 =M, [REDACTED]  
>  
> Hi Rich,  
> Can I call an electrician. We lost all 4 =all sconces that is lighting the tapestries  
on ground floor. I've been =orking on it since I can't find the short.  
>  
> Thanks  
>  
> =erwin Dela Cruz  
[REDACTED]  
>

</=iv>

</=lockquote>

From: "[REDACTED]" <[REDACTED]>  
<[REDACTED]>

Subject: Re: Electrician

Date: January 30, 2015 at 7:56:48 AM EST

To: Richard Kahn <richardkahn12@gmail.com>

Hi=Rich,  
I thought I sent you this email last =ight.

Lutron =o longer have parts for this type of system and they don't service them =nymore.  
I called my contact who is familiar with =utron and he said the only 2 options that we have is to  
upgrade the =ystem and the other one is to put a switch next to the panel to control =he 4 lights that are out.

The earliest he can get to the house is =onday to install a switch.

Thanks

Merwin Dela Cruz  
212-249-1122  
917-607-0626

Begin forwarded message:

From: =/b>"M\_delacruz68@yahoo.com" <m\_delacruz68@yahoo.com>

Date: =/b>January 30, 2015 at 1:30:45 PM =ST

Subject: =/b>Lutron =ontrol

To: =/b>Richard Kahn <richardkahn12@gmail.com>

Hi Rich,  
The =ottom switch with the red light, controls downlighting and the 4 lights =hat are out

Lights out

Lights out

This is the dimming panel where Zinon can put a switch to =ontrol those 4 lights.

Merwin Dela Cruz

212-249-1122  
917-607-0626

=