From:	Richard Barnett < ████████████
Sent:	Tuesday, May 14, 2013 10:14 PM
To:	jeffrey Epstein; ████████████
Subject:	9 East 71st Street Daily report 5/14

Here is the 9east 71st Daily rep=rt .1) Checked BMS off site system prior to arrival to 71st street checked=all system set points and settings monitoring chilled water valve function=AC-2 &AC- 3 holding set point over night. 2) Gave Con Edison access =o electric and gas meter readings.Took Steam readings may 13th 051552, M=y 14th 01552 no usage on high volumn line regular usage line May 13th 6427=, May 14th 64373 usage 99 units in normal range.3)called Monarch=Supply for update on steam trap order expected to arrive 5/16/13 #4) Sent =ella receipts for tools purchased for LSJ from Sears also Blue print copie= for air balancer Total Payment to AMEX $2765.05 5) called G &=3B G lighting ordered light bulbs for 9east Quote GG1078192 $520.47 =3B #6)Sent R Kahn request to review Proposal from S&E Scaffo=d to compare with York quote did not receive copy showing total scope of w=rk. 7) Sent York invoice for baker scaffold purchased to Rich Kahn=and scaffold installation & safety information for Michael a=d Ion scaffold project. 8) moved paintings from sues office to art storage=.9)Sent Rich Kahn E mail to see if Beaudin Ganze Zorro engineering=proposal was approved to check status for Exhaust fan installation=received no answer instead was questioned about my knowledge of the contra=t sent my reply .10) checked operation of 6th floor black out shades and m=vie theater all working normal. 11) checked low zone domestic water found =&G pump humming running hot shut off over night will check c=upling tomorrow and try to free up.12) Changed outside air filters for AC-= and Ac-3BR for preparation for air balance r. 13) changed belt s =160 for master bedroom ac blower for tomorrow air balance. 14) checked ser=er room ac unit running normal keeping set point 69 deg F . condensate pum= float hanging up took apart sump and fixed put back in operation.=br> =