

To: Richard Barnett [REDACTED]
From: Jeffrey Epstein
Sent: Tue 11/17/2009 7:06:20 PM
Subject: Re: Domestic hot water heater for master bedroom and upper floors at 71st street.

ok

On Tue, Nov 17, 2009 at 1:36 PM, Richard Barnett <[REDACTED]> wrote:

Hi Mr. Epstein ,The domestic water Patterson Kelly steam hot water heater that serves the master bedroom and upper floors at 71st street is not operating properly and is wasting steam due to the steam tube bundle leaking. I currently have the system valved off waiting for parts to be approved for the repair. I priced all parts needed for the repair the tube bundle is \$3778.50 ,re circulation pump is \$481.00 also the steam control valve may also need replacement ,Control Valve \$1800.00. I would like to replace the tube bundle and re circulation pump first to see if the existing control valve is operational if not than we would have to also order a new control valve. Last year I rebuilt the steam hot water heater that serves the lower floors (C-level 1st & 2nd) the parts that need to be replaced are from 1992
Thanks Richard.

Windows 7: I wanted simpler, now it's simpler. [I'm a rock star.](#)

--

The information contained in this communication is confidential, may be attorney-client privileged, may constitute inside information, and is intended only for the use of the addressee. It is the property of Jeffrey Epstein

Unauthorized use, disclosure or copying of this communication or any part thereof is strictly prohibited and may be unlawful. If you have received this communication in error, please notify us immediately by return e-mail or by e-mail to jeevacation@gmail.com, and destroy this communication and all copies thereof, including all attachments.