

**To:** Jeffrey Epstein[jeevacation@gmail.com]  
**From:** brice gordon  
**Sent:** Tue 9/11/2012 5:39:31 PM  
**Subject:** Clay Valve

FYI

As discussed, the clay valve which control water level at the main reservoir has failed. Therefore we can not control water levels or quality at the reservoir.

This in turn affects cooling tower operation and pool water quality. It is my understanding that it has been rebuilt several times.

I have arrange JBH to replace. Cost for valve \$4000.00 this included expedited shipping. Install should take a day.

--

**Brice Gordon**

**USVI**

Phone: [REDACTED]

**New Mexico**

Phone: [REDACTED]