

To: brice gordon [REDACTED]
From: Jeffrey Epstein
Sent: Fri 4/27/2012 5:58:23 PM
Subject: Re: Libray

thank you

On Fri, Apr 27, 2012 at 1:32 PM, brice gordon [REDACTED] wrote:

update on library system

1. both dehumidifiers where down, one needs a new condenser the other had was locked out and had to be reset

2. It has been determined that only one recirculating pump should be on at a time. when we commissioned the unit there was no mention at any time that we had to close this valve manual and rotate pumps monthly basic to much water passing over the coil to quickly. Trane did not even pick this up. !!

new condenser will be ordered, this should be covered by warranty. Will get David to review controls for dehumidifiers so we can view in mechanical room since units are in attic space

humidity down to 67% and dropping

--
Brice Gordon
Little Saint James
USVI
Phone: [REDACTED]

--

The information contained in this communication is confidential, may be attorney-client privileged, may constitute inside information, and is intended only for the use of the addressee. It is the property of Jeffrey Epstein
Unauthorized use, disclosure or copying of this communication or any part thereof is strictly prohibited and may be unlawful. If you have received this communication in error, please notify us immediately by return e-mail or by e-mail to jeevacation@gmail.com, and destroy this communication and all copies thereof,

including all attachments. copyright -all rights reserved