

To: Richard Kahn[REDACTED]
Cc: J Epstein[jeevacation@gmail.com]
From: Brice
Sent: Tue 10/16/2012 6:19:42 PM
Subject: Buck Steel

Rich

Danny and I have reviewed drawings from Buck Steel
Please note that the existing bolt pattern that is in place will have to be removed. and new anchors will need to be epoxied in to match shed from buck steel
I assume that Jeffrey is ok with Door placement

Would recommend Forward
Any concerns please call

Regards

Brice









Sent from my iPhone