

To: Brice Gordon [REDACTED]
Cc: Rich Kahn [REDACTED]
From: Jeffrey Epstein
Sent: Sun 3/23/2014 12:50:38 PM
Subject: Re: Heat Exchangers

ok, we serioulsy need industrial power conditioners. lets prioirtize

On Sun, Mar 23, 2014 at 6:49 AM, Brice Gordon [REDACTED] wrote:

Jeffrey
attached,

1. Estimate for cleaning and new seals for Two Heat Exchangers at Zorro
2. Photos of Heat Exchangers

The heat exchangers consist stainless steel plates compressed into the frame. The plates are separated by gaskets, which separates the cooling water from the heating water. It has become apparent that seals are failing as hot water is getting into our Cooling Tower Loop water. The last time the exchangers where cleaned was 6 years ago, no seals where changed at that time.

Material cost \$3846.00
Labor cost \$1440.00
Total Cost: \$5649.41 Tax included.

Lead Time for parts 5 days
Work will take 3 days, please note HVAC will be shut down over this time.

Can we proceed.

regards

Brice Gordon
[REDACTED]
Stanley, NM 87056
[REDACTED]

--

The information contained in this communication is confidential, may be attorney-client privileged, may constitute inside information, and is intended only for

the use of the addressee. It is the property of
Jeffrey Epstein

Unauthorized use, disclosure or copying of this
communication or any part thereof is strictly prohibited
and may be unlawful. If you have received this
communication in error, please notify us immediately by
return e-mail or by e-mail to jeevacation@gmail.com, and
destroy this communication and all copies thereof,
including all attachments. copyright -all rights reserved