

To: Jeffrey Epstein[jeevacation@gmail.com]
From: Richard Kahn
Sent: Wed 6/26/2013 8:18:51 PM
Subject: Fwd: Duct Investigation

not sure if Brice sent to you..

Richard Kahn
HBRK Associates Inc.
575 Lexington Avenue, 4th Floor,
New York, New York 10022
tel [REDACTED]
fax [REDACTED]
cell [REDACTED]

Begin forwarded message:

From: "Morgan Royce" <[REDACTED]>
Date: June 25, 2013 5:32:32 PM EDT
To: <[REDACTED]>
Cc: "Richard Kahn" <r[REDACTED]>
Subject: Duct Investigation

Brice/Richard,

I have been in contact with Courtney Eichhorst who did the ductwork investigation.
(Please mail the CD to the address below).

He has confirmed that none of the ductwork is collapsed or is corroded.

He mentioned that the return duct is large and connects to all four return grilles in the vertical and horizontal surfaces. There are no openings to any other areas.

He mentioned that the supply duct under slab terminates at a cap that is not secure and is causing the air flow into the wall chase.

He mentioned that the same supply duct has a rise under slab that has a cap that is compressed but does not appear to be restricting air flow.

All indications are that the ductwork is complete and can be reused without significant system effect.

Given the provided information on the existing ductwork I will finish up the report with options/costs for further discussion.

I hope to have the report complete soon after the Holiday. I would say next week but it is a short vacation week.

Thanks

Morgan B. Royce, PE | Associate Principal
BEAUDIN GANZE CONSULTING ENGINEERS, INC.

7007 Wyoming Blvd. NE, Suite F-2
Albuquerque, NM 87109



www.bgce.com

♻️ Please consider the environment before printing this email.

Watch for our NEW Website Coming Soon!

--

This message has been scanned for viruses and dangerous content by MailScanner, and is believed to be clean.