

To: [REDACTED]; Jeffrey  
Epstein[jeevacation@gmail.com]  
From: Roy Hodges  
Sent: Wed 5/29/2013 6:51:30 PM  
Subject: Fwd: Media Room A.C.

Please find Reefco's estimate for living room A/C replacement attached.

----- Forwarded message -----

From: reefcoservices <[REDACTED]>  
Date: Wed, May 29, 2013 at 11:54 AM  
Subject: Re: Media Room A.C.  
To: Roy Hodges <[REDACTED]>  
Cc: richardkahn12 <[REDACTED]>

Hello Roy,  
Attached is the Quote for the Media room A/C.  
The problem with the unit that is in there now is that its way too big and drops the temp fast but does not remove the humidity from the room. I suggest dropping the size from a 5 ton to a 3 ton unit. This will allow the unit to run longer and remove the moisture but also it will be large enough to cool the room even when occupied. To do the repair right, both the Air Handler, which is a ducted system located in the attic, and the Condenser will need to be changed. If you have any questions please feel free to give me a call or email US.

Regards,  
David Van Drieson  
Reefco Services

little St. James Media room Revised ac.xls

On Wed, May 29, 2013 at 9:18 AM, reefcoservices <[REDACTED]> wrote:

Good Morning Roy,  
Thank you for the opportunity to Quote AC for the Media Room. We will send the info this week.

Best regards,  
Tracy Van Drieson  
Reefco

On Wed, May 29, 2013 at 8:19 AM, Roy Hodges <[REDACTED]> wrote:

Good Morning Dave;

The boss is requesting the Media Room a.c. quote. Would you please forward when you have a minute?

Thank you,

--

Roy & Stephanie Hodges

--

Best regards,  
Tracy Van Drieson  
Reefco Services, Inc.

--

Best regards,  
Tracy Van Drieson  
Reefco Services, Inc.

--

Roy & Stephanie Hodges