

**To:** jeevacation@gmail.com[jeevacation@gmail.com];  
[REDACTED] jeffrey Epstein[jeevacation@gmail.com]  
**From:** Richard Barnett  
**Sent:** Fri 9/23/2011 9:43:08 PM  
**Subject:** RE: Siemens

Hi Rich we been working together all day , all panels are 100 % complete tested all system operations ,all of the contracted SCU work is complete . The only work left is the off site connection with apogee go , to control the BMS over the static ip address. We also found a problem with the Catering Kitchen exhaust fan which we will need to up grade the VFD drive to resolve operational problems from the range hood . I had siemens look at the system specifications to give a price for replacement. I will call you Monday to go over the additional work. Richard.

> From: [REDACTED]  
> Subject: Siemens  
> Date: Fri, 23 Sep 2011 15:56:44 -0400  
> To: [REDACTED]  
>  
> Did they come today to finish up?  
> If not let me know when they are coming next week  
> Thank you  
>  
> Richard Kahn  
> HBRK Associates Inc.  
> 301 East 66th Street, Suite 10F  
> New York, NY 10065  
> tel 646-862-4811  
> fax 646-350-0954  
> cell [REDACTED]  
>