

**To:** [redacted]; jeevacation@gmail.com[jeevacation@gmail.com]; jeffrey Epstein[jeevacation@gmail.com]; rich kahr [redacted]  
**From:** Richard Barnett  
**Sent:** Mon 8/8/2011 7:31:43 PM  
**Subject:** FW: Proposal?  
[1108141 9 East 71 street.pdf](#)

Mr. Epstein, during the Siemens SCU panel up grade the installation technician found your Bed room AC/unit controller not compatible with the new ethernet system. When Siemens priced the job they did not give a price to upgrade that controller, they didn't realize the MEC controller on the unit would not run on the ethernet system. Attached is a proposal for \$6863.00 to change the MEC control panel to run on the ethernet system. Richard.

---

**From:** [redacted]  
**To:** [redacted]  
**Date:** Mon, 8 Aug 2011 13:25:54 -0500  
**Subject:** RE: Proposal?

---

**From:** Richard Barnett [mailto:[redacted]]  
**Sent:** Monday, August 08, 2011 11:52 AM  
**To:** Rickert, Bradley  
**Subject:** Proposal?

Hi Bradley is there a proposal for the bedroom fan controller? If so please send. RichB