

From: Lesley Groff <[REDACTED]>
To: Daphne Wallace <[REDACTED]>
Cc: Bebe Avdiu <[REDACTED]>, Rich Kahn <[REDACTED]>
Subject: Re: LSJE, LLC secondary meter installation project - October 6, 2015
Date: Tue, 06 Oct 2015 22:52:21 +0000

thx

On Oct 6, 2015, at 6:43 PM, Daphne Wallace <[REDACTED]> wrote:

Keeping you in the loop, DW

----- Forwarded message -----

From: Allyson R. Gregory <[REDACTED]>
Date: Tue, Oct 6, 2015 at 5:41 PM
Subject: Re: LSJE, LLC secondary meter installation project - October 6, 2015
To: Daphne Wallace <[REDACTED]>
Cc: "Felix S. Rey" <[REDACTED]>, "Clinton T. Hedrington" <[REDACTED]>, ann
rodriguez <[REDACTED]>

Good Evening Daphne,

I'm currently working with various vendors to secure the 200:5 adjustable CT's for this project. The issue that I'm having is finding CT's that are big enough to wrap around the 6 wires per phase.

The alternative plan would be to de-energize the transformer and put standard sized CT's around the bushing. This would require an outage and you would have to go on generator power while this is being completed.

I will keep you posted and I will provide another update before the end of the week.

Please contact me on cell if you have any further questions. ([REDACTED])

Best,

Allyson Gregory
System Planning Manager
Virgin Islands Water & Power Authority

> On Oct 6, 2015, at 5:55 PM, "Daphne Wallace" <[REDACTED]> wrote:

>

> Greetings Ms. Gregory,

>

> We are still awaiting an update on where you are with the project.

>

> We fully understand that being this has not been done before research is needed, but we would appreciate any feedback as you proceed that we can give to our Principal that will help to keep him in the loop.

>

- > If we get nothing at all from you it looks as if we are not following up and doing our job.
- >
- > Please advise and kind regards, Daphne Wallace and Ann Rodriquez