

From: "Robert" <[REDACTED]>
To: "Norbert Kiss" <[REDACTED]>
Cc: "Lesley Groff" <[REDACTED]>

Subject: FW: Leslie Groff Master Bath - supports

Date: Fri, 06 Dec 2013 14:53:05 +0000

Attachments: DSCN6073.jpg

We need to do this to the vanities in the master bathroom. We should frame a knee wall under the cabinet. It will need to accommodate marble which will also need to be installed. Make it so that the marble will be recessed slightly under the cabinet. We can do this next week.

Bob

From: Chris Cross [mailto:[REDACTED]]
Sent: Friday, December 06, 2013 9:47 AM
To: Robert
Subject: Leslie Groff Master Bath - supports

Dear Bob:

Please find attached a photo looking down diagonally at the Vanity.

The support was constructed as per the Manufacturer's specs and the vanity seeing heavy daily use in our Showroom.

Contact me anytime.

Sincerely,

Chris Cross
[REDACTED]
[REDACTED]

132 Water Street South Norwalk CT

nukitchens.com

EFTA00378278

From: Robert [mailto: [REDACTED]]
Sent: Friday, December 6, 2013 6:53 AM
To: Chris Cross
Subject: RE: Leslie Groff Master Bath - supports

I think you should have made it clearer to the owner. Send me pictures. I still say it is not attached to the wall properly. That is your installers responsibility. The sheet rock should have been cut behind the cabinets and scabs should have been added to the studs to create a load bearing point on the end of the cabinets.

Robert Caffrey

Berkeley Construction LLC

[REDACTED] 12/6/13

From: Chris Cross [mailto: [REDACTED]]
Sent: Thursday, December 05, 2013 5:02 PM
To: Bob Caffrey
Subject: Leslie Groff Master Bath - supports

Dear Bob:

Sorry I couldn't take your call this morning, I was meeting with a customer.

Please find attached the info for the support. We have a working Vanity that has the same (tiled) support under the cabinet – can send photos if you'd like.

Let me know. Straight forward and easy.

Sincerely,

Chris Cross
[REDACTED]

EFTA00378279



132 Water Street South Norwalk CT

nukitchens.com