

John C. Cassidy Air Conditioning, Inc.
 846 W. 13th Court
 Riviera Beach, FL 33404
 [Redacted] Fax: [Redacted]
 CAC057321

07/15/17
 Page 1

NEPTUNE LLC
 358 EL BRILLO WY
 PALM BEACH FL 33480

NEPTUNE LLC
 358 EL BRILLO WY
 PALM BEACH FL 33480

Call Slip Number	Invoice Date	Invoice Number
422560	07/15/2017	S117501

Tech Date
 2598 07/15/2017

Qty	Description	Unit Price	Amount
(3)	NON-LISTED LABOR ONLY REPAIR (NO PARTS, PLEAS	134.00	402.00
(1)	SERVICE CHARGE	140.00	140.00

You saved \$99.00 as a preventive maintenance customer

 Brand Model Serial #
 TRANE 2TEE3F49A1000AA 7185YGYIV

Master bedroom unit has leak in evaporator coil and failed TXV as reported before. Unit is 10 years old and should be replaced rather than to repair. Customer needs quote to replace system. CU info FHP, em048-1csc, kh0426521.

ADDITIONAL DETAILS:

Customer call another ac company and they broke water supply line in wall. Chiseled out wall to get access to broken pipe. Repaired connection. Cleaned strainer and primed pump. Reset all water cooled units in house. Checked operation. System is normal at this time.



07/15/2017 19:13

Authorized Signature

As Agreed: 542.00