

From: Ann Rodriquez <[REDACTED]>
To: "jeffrey E." <jeevacation@gmail.com>
Subject: Fwd: Fuel Tank Room: Caribbean Protection
Date: Thu, 17 Sep 2015 15:49:04 +0000

Ann R.

Begin forwarded message:

From: "jeffrey E." <jeevacation@gmail.com>
Date: September 17, 2015 at 11:46:39 AM AST
To: ann rodriquez <[REDACTED]>
Subject: Re: Fuel Tank Room: Caribbean Protection

replace

On Thu, Sep 17, 2015 at 11:21 AM, ann rodriquez <[REDACTED]> wrote:
Hey Bossman,

Caribbean System Protection came out to look at our Fire Alarm system about a week ago. Our Power Supply is not working properly (Need new one), The ventilation fans are not working as they should & the strobes are not working at all.

New Power Supply: \$1,275.00
Labor could cost around: \$1,600.00 or more.

Please advise,
Ann R.

DISCLAIMER: The information contained in this e-mail may be privileged, confidential, and protected from disclosure. If you are not the intended recipient, you are hereby notified that any dissemination, distribution or duplication of this communication is strictly prohibited. If you have received this communication in error, please notify the sender immediately and delete all copies.

--

please note

The information contained in this communication is confidential, may be attorney-client privileged, may constitute inside information, and is intended only for the use of the addressee. It is the property of

JEE

Unauthorized use, disclosure or copying of this communication or any part thereof is strictly prohibited and may be unlawful. If you have received this communication in error, please notify us immediately by return e-mail or by e-mail to jeevacation@gmail.com, and

destroy this communication and all copies thereof,
including all attachments. copyright -all rights reserved