

From: brice gordon <[REDACTED]>

To: Jeffrey Epstein <jeevacation@gmail.com>

Cc: TOM MELNICK <[REDACTED]>

Subject: Genset Sound Proofing

Date: Thu, 02 Feb 2012 14:12:32 +0000

Attachments: Genset_Sound_Proof02022012_00000.pdf

attached drawing outlining recommendation for the sound proofing of the Gensets
basically we would add an interior wall, then this space would be lined with 3" thick sound proofing material
drawing has been sent to obtain cost for sound proofing material.

Spray on solution is not recommended for this type of application/situation

can we proceed with building interior wall in the mean time, this would at least create a baffle and cut some
noise down.?

--

Brice Gordon

Little Saint James

USVI

Phone [REDACTED]