

**From:** Richard Kahn <[REDACTED]>

**To:** "jeffrey E." <jeevacation@gmail.com>

**Subject:** Fwd: LSJ Cistern Pumps

**Date:** Wed, 15 Mar 2017 21:43:44 +0000

**Attachments:** Poly\_Caribe\_II\_\_\$4,345.00\_03.15.17\_Inv.\_4994.pdf

---

cistern pumps blew - cost 4,345  
appears from my perspective to be a danny issue  
brice in email below seems bewildered..

Richard Kahn  
HBRK Associates Inc.  
575 Lexington Avenue 4th Floor  
New York, NY 10022  
tel [REDACTED]  
fax [REDACTED]  
cell [REDACTED]

Begin forwarded message:

**From:** LSJ <[REDACTED]>

**Subject:** Re: LSJ Cistern Pumps

**Date:** March 15, 2017 at 5:39:45 PM EDT

**To:** Richard Kahn <[REDACTED]>

**Cc:** [REDACTED] <[REDACTED]>

No

But not unexpected as there was no low level limit switches installed when new pumps were installed  
The limit switches or low suction limit switches would turn pumps off if water level in cistern got below a certain set point

As stated before, There should also be variable speed drives installed on the pumps, this would stop hammering on water the system

Duane and I observed cisterns get to very low levels and the pumps had to be manually turned

I did mention this to Danny? But got the normal BS answer

After today's call with Boss it probably best I advise you fully of the situation and not be on calls  
Otherwise I'm going to have a target on my back for the rest of my life

Let's talk tomorrow

BRIVE

Sent from my iPhone

On Mar 15, 2017, at 3:03 PM, Richard Kahn <[REDACTED]> wrote:

are you aware they blew?  
lets discuss and get danny and anna on the phone for a discussion  
thanks

<Poly Caribe II \_\$4,345.00\_03.15.17\_Inv.#4994.pdf>

Richard Kahn  
HBRK Associates Inc.  
575 Lexington Avenue 4th Floor  
New York, NY 10022  
tel [REDACTED]  
fax [REDACTED]  
cell [REDACTED]

Begin forwarded message:

**From:** Richard Kahn <[REDACTED]>  
**Subject:** LSJ Cistern Pumps  
**Date:** March 15, 2017 at 5:03:29 PM EDT  
**To:** LSJ <[REDACTED]>

are you aware they blew?  
lets discuss and get danny and anna on the phone for a discussion  
thanks

Richard Kahn  
HBRK Associates Inc.  
575 Lexington Avenue 4th Floor  
New York, NY 10022  
tel [REDACTED]  
fax [REDACTED]  
cell [REDACTED]

