

**From:** Ann Rodriquez [REDACTED]  
**To:** "jeffrey E." <[jeevacation@gmail.com](mailto:jeevacation@gmail.com)>  
**Cc:** Daphne Wallace [REDACTED], Rich Kahn [REDACTED]  
**Subject:** Re: LSJ Main Generators: Not good  
**Date:** Wed, 02 Aug 2017 21:01:50 +0000

---

yes

Ann R.

On Aug 2, 2017, at 4:46 PM, jeffrey E. <[jeevacation@gmail.com](mailto:jeevacation@gmail.com)> wrote:

Bad maintenance

On Wed, Aug 2, 2017 at 3:21 PM Ann Rodriquez [REDACTED] wrote:

Hey Bossman,

Danny just told me that the 1st generator sprung a coolant leak (first 6 photos) and the 2nd Generator belt has burst (photos 7&8) 2nd Generator is down. LSJ is currently running on 1 generator at the moment.

He asked if Tap can fix it for him. Tap said it's pretty bad but he can fix it if we get all the parts. I told Danny V. to call Plan B Generator company to come out tomorrow morning or asap.

The Generator is running because we had another power outage this morning and it blew out the repeater for the R/O again. (last 2 photos)

Not to worry I'm on it...  
Ann R.

--  
please note

The information contained in this communication is confidential, may be attorney-client privileged, may constitute inside information, and is intended only for the use of the addressee. It is the property of JEE

Unauthorized use, disclosure or copying of this communication or any part thereof is strictly prohibited and may be unlawful. If you have received this communication in error, please notify us immediately by return e-mail or by e-mail to [jeevacation@gmail.com](mailto:jeevacation@gmail.com), and destroy this communication and all copies thereof, including all attachments. copyright -all rights reserved