

From: Roy Hodges <[REDACTED]>

To: Jeffrey Epstein <[REDACTED]>

Subject:

Date: Sun, 30 Jun 2013 12:35:21 +0000

Water should be back up and running. I think there are some things we could do to make the system more reliable. On paper, there are 3 pumps and that should give plenty of redundancy. In reality, the pumps share the same feed lines and control system. So if it gets air into the feed line or there is an electrical issue, all three fail. Last night was electrical and tonight air somehow got into the feed line. I'll try to put together some ideas.

--

Roy & Stephanie Hodges