

**From:** Richard Barnett <[REDACTED]>

**To:** jeffrey Epstein <[REDACTED]>

**Subject:** RE:

**Date:** Thu, 27 Jun 2013 14:30:03 +0000

**Importance:** Normal

---

Mr.Epstein i am working on the issue of air flow yesterday reviewed the blue prints for the 4th floor Gym the floor vents are rated at a low 325cfm of air each ,at that time the room temperature was71deg f set point for room was 71deg f checked the supply duct zone opened access panels checked for obstructions of air flow found no dampers closed from the discharge duct turning down to the 4th fl supply .I also cleaned the reheat coil that is in the discharge air flow to make sure of no blockages set the room thermostat to 67.deg f room temperature is 67.deg f making set point I am still investigating to see if i can increase the ammount flow of air in the room .Richard

---

Date: Thu, 27 Jun 2013 10:13:00 -0400

Subject:

From: jeevacation@gmail.com

To: [REDACTED]

no air in gymm at all

--

\*\*\*\*\*

The information contained in this communication is confidential, may be attorney-client privileged, may constitute inside information, and is intended only for the use of the addressee. It is the property of Jeffrey Epstein

Unauthorized use, disclosure or copying of this communication or any part thereof is strictly prohibited and may be unlawful. If you have received this communication in error, please notify us immediately by return e-mail or by e-mail to [jeevacation@gmail.com](mailto:jeevacation@gmail.com), and destroy this communication and all copies thereof, including all attachments. copyright -all rights reserved