

From: Brice <[REDACTED]>
To: Richard Kahn <[REDACTED]>
Cc: J Epstein <jeevacation@gmail.com>

Subject: Buck Steel

Date: Tue, 16 Oct 2012 18:19:42 +0000

Inline-Images: photo_1.JPG; photo_2.JPG; photo_3.JPG; photo_4.JPG

Rich

Danny and I have reviewed drawings from Buck Steel

Please note that the existing bolt pattern that is in place will have to be removed. and new anchors will need to be epoxied in to match shed from buck steel

I assume that Jeffrey is ok with Door placement

Would recommend Forward

Any concerns please call

Regards

Brice

Sent from my iPhone 

