

From: Richard Kahn <[REDACTED]>
To: ann rodriquez <[REDACTED]>
Cc: Zorro Ranch <[REDACTED]>
Subject: Re: Update on the Transformer
Date: Thu, 05 Nov 2015 16:19:27 +0000

thank you for update
did mr brian bring quote for 500amp KVA transformer this am?
if so please send

thank you

Richard Kahn
HBRK Associates Inc.
575 Lexington Avenue 4th Floor
New York, NY 10022
tel [REDACTED]
fax [REDACTED]
cell [REDACTED]

On Nov 5, 2015, at 11:15 AM, Ann Rodriquez <[REDACTED]> wrote:

Sorry, I was at the Main Post office on St. Thomas when they arrived to LSJ with Danny, They came over this morning did the test and left. Danny said our transformer failed the test and isn't any good. :(

Brian's Electric and Mr.Felix said they will send us a report on their findings. I'll forward the reports to you and Brice along with their contact info as soon as I get it or we can call them together at 1:15pm.

Please advise,
Ann R.

Sent from my iPhone

On Nov 5, 2015, at 10:26 AM, Richard Kahn <[REDACTED]> wrote:

thanks for update
before brian and mr felix leave can you please have them speak with brice today so he is up to date with their thoughts
thanks

Richard Kahn
HBRK Associates Inc.
575 Lexington Avenue 4th Floor
New York, NY 10022
tel [REDACTED]

fax [REDACTED]
cel [REDACTED]

On Nov 4, 2015, at 4:52 PM, Ann Rodriquez <[REDACTED]> wrote:

Mr. Brian said he will bring the quote in the morning. I'm not sure how he's calculating the savings but I'll ask him in the morning.

Mr. Felix at WAPA said that our Transformer is only using about 15-20% of its capacity and Mr. Brian confirmed that the 500amp KVA will be more than sufficient for the Island.

Sent from my iPhone

On Nov 4, 2015, at 5:41 PM, Richard Kahn <[REDACTED]> wrote:

any update on quote?
50% savings sound nice however how is that amount determined?
please advise
thanks

Richard Kahn
HBRK Associates Inc.
575 Lexington Avenue 4th Floor
New York, NY 10022
[REDACTED]

On Nov 4, 2015, at 10:05 AM, Ann Rodriquez <[REDACTED]> wrote:

Hi Rich,

Bossman would like us to purchase the 500amp KVA transformer. I'm calling Bryan for a quote right now.

Ann R.
Sent from my iPhone

Begin forwarded message:

From: "jeffrey E." <jeevacation@gmail.com>
Date: November 4, 2015 at 10:42:36 AM AST
To: Ann Rodriquez <[REDACTED]>

Subject: Re: Update on the Transformer

ok to all

On Wed, Nov 4, 2015 at 9:38 AM, Ann Rodriquez <[REDACTED]> wrote:

Hey Bossman,

Bryan said his loaner is 300amp KVA and we should be running on a 500amp KVA but we're running on 1500amp KVA, He said if we change immediately to a 500amp KVA we would save up to 50% a month on our electrical bill because we're paying for unused electricity.

Bryan is unable to come out today because Mr. Felix said he would like a WAPA guy to be present during the test. They will come out tomorrow morning at 9am to run the test.

Please advise,
Ann R.

Sent from my iPhone

--

please note

The information contained in this communication is confidential, may be attorney-client privileged, may constitute inside information, and is intended only for the use of the addressee. It is the property of

JEE

Unauthorized use, disclosure or copying of this communication or any part thereof is strictly prohibited and may be unlawful. If you have received this communication in error, please notify us immediately by return e-mail or by e-mail to jeevacation@gmail.com, and destroy this communication and all copies thereof, including all attachments. copyright -all rights reserved