

From: [REDACTED] <[REDACTED]>

To: Jeffrey Epstein <jeevacation@gmail.com>

Cc: Rich Kahn <[REDACTED]>, LSJ GSJ <[REDACTED]>

Subject: LSJ Cabana 4 Roof

Date: Mon, 02 Jul 2018 12:37:34 +0000

Attachments: IMG_2058.jpg

Attached Photo's: Cabana 4 Roof

A good percentage of the screws holding the roof down, especially on the prevailing wind side are failing. Do we replace as per existing material, except upgrade to Stainless screws.?

regards Brice

--

[REDACTED]
The Saint James Group
USVI

Ph: [REDACTED]