

From: brice gordon <[REDACTED]>

To: Jeffrey Epstein <jeevacation@gmail.com>

Cc: Rich Kahn <[REDACTED]>, michael glidden <[REDACTED]>, LSJ GSJ
<[REDACTED]>

Subject: LSJ Genset 2 Failure

Date: Wed, 20 Jun 2018 15:32:39 +0000

Attachments: LSJ_Genset_2_Main_Winding.jpg

Good afternoon

Attached photo of Damage to Main Winding on Generator 2

As discussed Generator 2 went off line yesterday during an electrical storm.

The Main winding on the Generator Portion of the Genset Failed.

To Maintain Operation of Generator Two, Plan B will service Generator Portion of Genset 1 and swap out with damaged Back End from Generator 2.

The Back End/winding will be removed completely and sent to St Thomas to be repaired.

regards

Brice Gordon
The Saint James Group
USVI

Ph: [REDACTED]