

From: "jeffrey E." <jeevacation@gmail.com>
To: Rich Kahn <[REDACTED]>
Subject: Fwd: LSJ Genset 2 Failure
Date: Wed, 20 Jun 2018 15:34:37 +0000

Review emails since march re rebuild schedule i!!!!

----- Forwarded message -----

From: brice gordon <[REDACTED]>
Date: Wed, Jun 20, 2018 at 5:32 PM
Subject: LSJ Genset 2 Failure
To: Jeffrey Epstein <jeevacation@gmail.com>
CC: Rich Kahn <[REDACTED]>, michael glidden <[REDACTED]>, LSJ GSJ <[REDACTED]>

Good afternoon

Attached photo of Damage to Main Winding on Generator 2

As discussed Generator 2 went off line yesterday during an electrical storm.
The Main winding on the Generator Portion of the Genset Failed.
To Maintain Operation of Generator Two, Plan B will service Generator Portion of Genset 1 and swap out with damaged Back End from Generator 2.
The Back End/winding will be removed completely and sent to St Thomas to be repaired.

regards

Brice Gordon
The Saint James Group
USVI

Ph: [REDACTED]

--

please note

The information contained in this communication is confidential, may be attorney-client privileged, may constitute inside information, and is intended only for the use of the addressee. It is the property of JEE

Unauthorized use, disclosure or copying of this communication or any part thereof is strictly prohibited and may be unlawful. If you have received this communication in error, please notify us immediately by return e-mail or by e-mail to jeevacation@gmail.com, and destroy this communication and all copies thereof, including all attachments. copyright -all rights reserved