

From: J <jeevacation@gmail.com>

To: Kyle reavis <[REDACTED]>

Cc: Richard Kahn <[REDACTED]>, [REDACTED] <[REDACTED]>, [REDACTED] <[REDACTED]>, LSJ Michael Glidden <[REDACTED]>

Subject: Re: Cabana 3 and 4 Plumbing Issue

Date: Wed, 19 Dec 2018 17:43:00 +0000

little i can say

On Wed, Dec 19, 2018 at 11:43 AM Kyle reavis <[REDACTED]> wrote:

Good Morning,

The plumbing for the showers in cabana 3 and 4 were run incorrectly by JPKs plumber Brian. He tied in both the hand held shower head and the main shower head into one line instead of two. This means that when you turn on the handle (there are 2) that water comes out of both shower heads. The only way to fix cabana 3 is to remove tiles and split the line the correct way. In cabana 4 they can access the pipes from the backside of the shower wall leaving the tiles in tack. They are going to start the split in 4 first today. I am going to check now to see if we have enough tile to do cabana 3. The plumbing in 1 and 2 were tested today also and have no issues, these two were plumbed by JPKs plumber Jon. We will have Jon do the fix in 3 and 4. Until they open the wall I cannot give an end date on this work. I suggest no payments made to JPK until the work is completed, I know that Jay had paid Brian for all of this work as completed. Jay will be notified by email of these issues immediately.

Very Respectfully,

Kyle Reavis

--

please note

The information contained in this communication is confidential, may be attorney-client privileged, may constitute inside information, and is intended only for the use of the addressee. It is the property of JEE

Unauthorized use, disclosure or copying of this communication or any part thereof is strictly prohibited and may be unlawful. If you have received this communication in error, please notify us immediately by return e-mail or by e-mail to jeevacation@gmail.com, and destroy this communication and all copies thereof, including all attachments. copyright -all rights reserved