

From: michael glidden <[REDACTED]>

To: J <jeevacation@gmail.com>

Cc: Richard Kahn <[REDACTED]>, Brice <[REDACTED]>, LSJ GSJ
<[REDACTED]>

Subject: WAPA switch

Date: Mon, 17 Dec 2018 19:41:57 +0000

Good day.

The high voltage switch was replaced with the new one this morning. Generator #2 had been designated as the primary back up unit and came on line as expected this morning around 6 am when wapa shut down the feeder and ran until approximately 11:30 am when wapa switched back on.