

From: Kyle reavis <[REDACTED]>

To: "jeffrey E." <jeevacation@gmail.com>

Subject: Engineering Rust

Date: Fri, 19 Oct 2018 11:57:39 +0000

Attachments: IMG_20181019_072453.jpg; IMG_20181019_072456.jpg; IMG_20181019_072528.jpg;
IMG_20181019_072519.jpg

Good Morning Mr Epstein,

Please see the rust pictures of engineering / wreck shop. We have structural columns that have been completely compromised due to rust. All the joist have rust on the butt joints. It is my professional opinion that this area is demolished and a concrete structure replaces it. I am sending the other buldings now, they are better in comparison.

Very Respectfully,

Kyle