

**From:** J <jeevacation@gmail.com>

**To:** Jermaine Ruan <[REDACTED]>

**Subject:** Re: Flagpole pool

**Date:** Sat, 23 Feb 2019 16:07:51 +0000

---

Yes

On Sat, Feb 23, 2019 at 10:30 AM Jermaine Ruan <[REDACTED]> wrote:

Good day boss

As per your requested myself and tap is working on the audio system from the rack it shelf ( the floor is being worked on and your desk removed for safety) Tap ask if we can bring a sound guy that he knows to look at the power distribution tomorrow afternoon.

We noticing the ceiling light slightly blinking while we were testing the speakers. This guy helped him with a similar issue at the club he plays at. While talking to him on the phone he didn't like the fact that the rack was not on it's own independent breaker box vs the main box. We especially notice it when testing the subs. Do we have permission to do so?

Regards  
Jruan

Sent from my iPhone

--

please note

The information contained in this communication is confidential, may be attorney-client privileged, may constitute inside information, and is intended only for the use of the addressee. It is the property of JEE

Unauthorized use, disclosure or copying of this communication or any part thereof is strictly prohibited and may be unlawful. If you have received this communication in error, please notify us immediately by return e-mail or by e-mail to [jeevacation@gmail.com](mailto:jeevacation@gmail.com), and destroy this communication and all copies thereof, including all attachments. copyright -all rights reserved