

**From:** Merwin Dela cruz <[REDACTED]>

**To:** "jeffrey E." <jeevacation@gmail.com>

**Subject:** Re:

**Date:** Tue, 14 Feb 2017 12:54:58 +0000

---

Good morning sir,

There was air in the system that's why the valve regulator on the 4th floor got stuck and had to be reset.

Merwin Dela Cruz  
[REDACTED]  
[REDACTED]

On Feb 14, 2017, at 7:23 AM, jeffrey E. <[jeevacation@gmail.com](mailto:jeevacation@gmail.com)> wrote:

what happenedf

--

please note

The information contained in this communication is confidential, may be attorney-client privileged, may constitute inside information, and is intended only for the use of the addressee. It is the property of JEE

Unauthorized use, disclosure or copying of this communication or any part thereof is strictly prohibited and may be unlawful. If you have received this communication in error, please notify us immediately by return e-mail or by e-mail to [jeevacation@gmail.com](mailto:jeevacation@gmail.com), and destroy this communication and all copies thereof, including all attachments. copyright -all rights reserved