

Reefco Services, Inc.

St. Thomas, VI, 00802-6463

# Invoice

Date	Invoice #
8/6/2015	109457

<b>Bill To</b>
Little Saint James

<b>Ship To</b>

P.O. Number	Terms	Rep	Ship	Via	F.O.B.	Project
Little Saint James	Due on receipt	TG	8/7/2015			

Quantity	Item Code	Description	U/M	Price Each	Amount
1	MCLSJ	Maintenance Little Saint James Preventive Maintenance (PM) for August. Checked for proper operation on all units. Checked pressures, changed or cleaned filters, fan coils cleaned. *found Gym unit frozen up, checked pressure next day, found unit very low on R22. Probable leak on evaporator coil. Anna has photo's. **Cabana #1 (repl) unit is ordered, will try to install next week.		1,550.00	1,550.00

<b>Phone #</b>	<b>Fax #</b>	<b>E-mail</b>	<b>Total</b>	\$1,550.00
----------------	--------------	---------------	--------------	------------

		reefcoervices@gmail.com
--	--	-------------------------

# REEFCO SERVICES, INC

Marine Refrigeration & Air Conditioning  
Reverse Osmosis Desalination Systems

109457

3801 Crown Bay, Suite 210  
St. Thomas USVI 00802  
Phone/Fax: [REDACTED]  
E: reefcoservices@gmail.com

NAME/VESSEL/HIN# LSJ island		DEPT. 01	DATE Aug 6/15	
CONTACT/PHONE ANNA [REDACTED]		LOCATION LSJ island		
BRAND NAME	MODEL #	SERIAL #		
TECH Tom	PAYMENT TYPE	AUTH. #		
DATE	DESCRIPTION	PRICES	AMOUNT	
	Preventive MAINTENANCE FOR AUGUST			
	Checked for proper operation ON ALL UNITS. Checked Pressures, changed or cleaned filters, FAN COILS CLEANED			
	⊗ Found GYM UNIT FROZEN UP, checked pressure next day, Found unit very low ON R-22. PROBABLE LEAK ON EVAPORATOR COIL. ANNA HAS PHOTO'S			
	⊗ CABANA #1 UNIT IS ORDERED, WILL TRY TO INSTALL NEXT WEEK			
	TOTAL For Aug. P.M., INC Filters & Cleaning Product			\$ 1550.00

SIGNATURE

WE APPRECIATE YOUR BUSINESS  
[www.reefco.net](http://www.reefco.net)