

Analytical Report

Lab Order 1404128

Date Reported: 4/9/2014

Hall Environmental Analysis Laboratory, Inc.

CLIENT: Zorro Development
Project: Domestic Water ZDC
Lab ID: 1404128-001

Client Sample ID: MH Kitchen
Collection Date: 4/2/2014 1:20:00 PM
Received Date: 4/2/2014 3:45:00 PM

Matrix: AQUEOUS

Analyses	Result	RL	Qual	Units	DF	Date Analyzed	Batch
EPA METHOD 300.0: ANIONS							Analyst: JRR
Nitrogen, Nitrate (As N)	0.31	0.10		mg/L	1	4/3/2014 12:40:32 AM	R17766
EPA 200.8: METALS							Analyst: DBD
Arsenic	ND	0.0010		mg/L	1	4/7/2014 11:00:35 AM	R17835
Lead	ND	0.0010		mg/L	1	4/7/2014 11:00:35 AM	R17835
Copper	0.16	0.0050		mg/L	5	4/7/2014 2:39:46 PM	R17835
SM 9223B TOTAL COLIFORM							Analyst: SMS
Total Coliform	Absent	0		P/A	1	4/3/2014 5:45:00 PM	12518
E. Coli	Absent	0		P/A	1	4/3/2014 5:45:00 PM	12518

Refer to the QC Summary report and sample login checklist for flagged QC data and preservation information.

Qualifiers:	* Value exceeds Maximum Contaminant Level.	B Analyte detected in the associated Method Blank
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	ND Not Detected at the Reporting Limit
	O RSD is greater than RSDlimit	P Sample pH greater than 2.
	R RPD outside accepted recovery limits	RL Reporting Detection Limit
	S Spike Recovery outside accepted recovery limits	

Hall Environmental Analysis Laboratory, Inc.

CLIENT: Zorro Development
 Project: Domestic Water ZDC
 Lab ID: 1404128-002

Client Sample ID: Lodge
 Collection Date: 4/2/2014 1:30:00 PM
 Received Date: 4/2/2014 3:45:00 PM

Matrix: AQUEOUS

Analyses	Result	RL	Qual	Units	DF	Date Analyzed	Batch
EPA METHOD 300.0: ANIONS							Analyst: JRR
Nitrogen, Nitrate (As N)	1.8	0.10		mg/L	1	4/3/2014 1:30:11 AM	R17766
EPA 200.8: METALS							Analyst: DBD
Arsenic	0.0020	0.0010		mg/L	1	4/7/2014 11:15:45 AM	R17835
Lead	ND	0.0010		mg/L	1	4/7/2014 11:15:45 AM	R17835
Copper	0.010	0.0010		mg/L	1	4/7/2014 11:15:45 AM	R17835
SM 9223B TOTAL COLIFORM							Analyst: SMS
Total Coliform	Present	0		P/A	1	4/3/2014 5:45:00 PM	12518
E. Coli	Absent	0		P/A	1	4/3/2014 5:45:00 PM	12518

Refer to the QC Summary report and sample login checklist for flagged QC data and preservation information.

Qualifiers:	* Value exceeds Maximum Contaminant Level.	B Analyte detected in the associated Method Blank	
	E Value above quantitation range	H Holding times for preparation or analysis exceeded	
	J Analyte detected below quantitation limits	ND Not Detected at the Reporting Limit	Page 2 of 7
	O RSD is greater than RSDlimit	P Sample pH greater than 2.	
	R RPD outside accepted recovery limits	RL Reporting Detection Limit	
	S Spike Recovery outside accepted recovery limits		